



## **ANALYSIS OF TREND CHANGES IN DEGREE-DAY VALUES OF HEATING AND COOLING: BROILER BREEDING CASE**

*Ali Yucel<sup>1</sup>, Atilgan Atilgan<sup>2</sup>, Nuri Erdem<sup>1</sup>, Hasan Oz<sup>2</sup>*

*<sup>1</sup>Osmaniye Korkut Ata University, Osmaniye, Turkey, <sup>2</sup>Suleyman Demirel University, Isparta, Turkey*

### **Abstract**

An ideal broiler house should be designed to minimize the effects of weather changes and to keep indoor conditions at the comfort temperature of the animals. In this case, this should be done with minimum cost and possible lowest operating costs. Degree-day methods are used in order to have knowledge of the energy need of any structure. With this method, the measured values or meteorological data can be used to give information about the heating and cooling energy quantities of structures. Depending on the climate change in recent years, the changes need to be examined that have taken place in order to provide optimum comfort in animal barn. Isparta province and districts were selected as the study area. The long-term average daily temperature values are used from meteorological stations of the selected region. The heating and cooling degree day values were calculated for selected balance temperatures in broiler breeding. Linear Regression Analysis and Spearman Rank Correlation Test were conducted to determine the changes of these values due to climate change. In conclusion, it was determined that there were statistically significant trends at 5% significance level in Egirdir (21°C), Isparta (31-29-25 and 23°C), Kasimlar (18°C), Senirkent (31-29-25-23 and 21°C), Sutculer (all selected balance temperature values) and Yalvac (31-29-25-23 and 21°C) in terms of heating degree-day values, and in Atabey (29-25-23-21 and 18°C), Barla (25-23 and 21°C), Isparta (23-21 and 18°C), Senirkent (29-25-23-21 and 18°C), Sutculer (29-25-23-21 and 18°C), Sarkikaraagac (25-23-21 and 18°C), Uluborlu (25-23-21 and 18°C) and Yalvac (25-23-21

and 18°C) in terms of cooling degree-day values. As a result, it has been concluded that more energy consumption will be a concern for heating and cooling of the broiler house that will be built in the province of Isparta.

**Key words:** Broiler, Linear Regression Analysis, Spearman Rank Correlation Test, Temperature, Trend analysis

## INTRODUCTION

Controlling indoor temperatures in broiler breeding in all seasons increases the comfort and productivity of living beings. The main duty of an agricultural structure is to protect the creatures living in it against the climate. An ideal agricultural structure must minimize climatic changes and regulate the indoor weather conditions according to the optimum requirements of the creatures living inside it all the time.

The degree-day method is commonly used in residential, commercial and industrial buildings as well as greenhouses, breeding facilities, storage facilities to estimate the energy consumption for heating and cooling (Yildiz and Sosaoglu, 2007). The heating and cooling degree-day method depends on providing optimum climatic conditions in broiler poultry houses and interpreting the climatic conditions in the region where the structure is located in a good way (Kuehn *et al.* 1998).

Information on temperature which is the main element of the climate has great importance in determining the characteristics of global climatic variations. The temperature phenomenon indicates great variability on both spatial and temporal scales. These changes reveal significant hints for understanding the general structure of the climate. Therefore, recently, studies on climatic changes have focused on the trend analyses of this parameter (Turkes, 1996; Kadioglu, 1997; Turkes, 2002; Bagdatli *et al.* 2014).

Recently, some non-parametric statistical tests such as the Sen's T-test, Spearman's Rho test, Linear Regression, Mann-Kendall, Seasonal Kendall, Mann-Whitney and Kruskal-Wallis H tests have been commonly used to identify temperature change trends and to take due precautions for changes (Kalayci and Kahya 1998; Demir *et al.*, 2016).

The aim of this study was to determine the trend changes in the degree-day values prepared by examining the long-term meteorological data. Linear regression analysis and Spearman rank correlation test were applied to determine trends in heating and cooling degree-day values.

## MATERIAL AND METHOD

In the study, long-term (1929-2015) average daily temperature values belonging to 16 meteorological stations including Isparta and districts were used (Table 1). Heating and cooling values were calculated using the degree-of-day method for the current or future broiler breeding in the region. Most common and easy parametric method Linear Regression Analysis (LRA) and non-parametric method Spearman Rank Correlation Test (SRCT) were applied in order to determine the trend changes in the calculated heating and cooling degree-day values.

**Table 1.** Characteristics of meteorological stations and observation lengths

| Meteorological stations | Observation lengths | Latitude (Degree) | Longitude (Degree) | Elevation (m) |
|-------------------------|---------------------|-------------------|--------------------|---------------|
| Aksu                    | 1983 – 2003         | 37°47'            | 31°04'             | 1240          |
| Atabey                  | 1968 – 2015         | 37°57'            | 30°38'             | 1000          |
| Bagkonak                | 1987 – 1996         | 38°14'            | 31°17'             | 1397          |
| Barla                   | 1987 – 1992         | 38°01'            | 30°78'             | 1085          |
| Egirdir                 | 1968 – 2015         | 37°50'            | 30°52'             | 917           |
| Gelendost               | 1983 – 1988         | 38°07'            | 31°01'             | 952           |
| Isparta Center          | 1929 – 2015         | 37°47'            | 30°34'             | 997           |
| Kasımlar                | 1987 – 1993         | 37°53'            | 31°19'             | 1070          |
| Keciborlu               | 1971 – 1990         | 37°57'            | 30°18'             | 996           |
| Kumdanli                | 1984 – 1995         | 38°32'            | 30°97'             | 1029          |
| Senirkent               | 1970 – 2015         | 38°06'            | 30°33'             | 959           |
| Sutculer                | 1968 – 2015         | 37°30'            | 30°59'             | 975           |
| Sarkikaraagac           | 1976 – 2015         | 38°05'            | 31°22'             | 1180          |
| Uluborlu                | 1968 – 2015         | 38°05'            | 30°27'             | 1025          |
| Yalvac                  | 1972 – 2015         | 38°16'            | 31°10'             | 1096          |
| Yenisarbademli          | 1983 – 1994         | 37°42'            | 31°23'             | 1183          |

In our country, an average 6 week growing period is applied in broiler breeding. Heating and cooling degree-day values are calculated according to the recommended and selected balance temperature (Table 2) values during these growing periods (Lindley and Whitaker, 1996; Atilgan *et al.*, 2012; Anonymous, 2015)

**Table 2.** Recommended values for inside and selected balance temperatures for broiler chickens.

| Week | Recommended inside temp. (°C) | Selected balance temp. (°C) |
|------|-------------------------------|-----------------------------|
| 1    | 32-30                         | 31                          |
| 2    | 30-28                         | 29                          |
| 3    | 26-24                         | 25                          |
| 4    | 24-22                         | 23                          |
| 5    | 22-20                         | 21                          |
| 6    | 19-17                         | 18                          |

### Degree-Day Method

In the degree-day method, a certain value of the balance point temperature must first be determined. The balance temperature is the outside temperature when no heating or cooling is needed. Energy calculations are performed for periods where the outdoor temperature is lower and higher than the balance point temperature. Depending on the selected different balance temperature ( $T_b$ ) values for broiler breeding, it can be assumed that the energy required for heating and cooling is directly proportional to the difference between the outside temperatures ( $T_o$ ). Thus, during the growing season, the amount of energy required for heating or cooling according to different average balance temperature values can be estimated in each growing period. Heating and cooling degree-day (HDD, CDD) can be calculated via this equation 1 and 2, respectively (Gultekin, 1995; Satman and Yalcinkaya, 1999; Buyukalaca *et al.*, 2001; Krese *et al.*, 2012; Yucel *et al.*, 2014; Aydin *et al.*, 2015; Erturk *et al.*, 2015).

$$HDD = \sum_{i=1}^n (T_b - T_o)^+ \tag{1}$$

$$CDD = \sum_{i=1}^n (T_o - T_b)^+ \tag{2}$$

Here;  $T_o$  outside temperature (°C),  $T_b$  the recommended inside and selected balance temperatures (°C) given in Table 1,  $n$  the days of the year, (+) the mark in the equations above suggests that only the positive values will be used.

### Linear Regression Analysis (LRA)

LRA is a parametric test that determines the relationship between two or more dependent and independent variables that have a causal link. It is also a mathematical model designed to make predictions (Helsel and Hirsch, 1993;

Hamdi *et al.*, 2009; Shammugasundram, 2012; Singh *et al.*, 2015). Simple linear regression equation:

$$Y = a + bX \quad (3)$$

Here, Y, X, a, and b indicate dependent variable, independent variable, intercept and trend respectively. The significance of the analysis is tested by the t test, a parametric test that assumes that the data are normally distributed. With this test, it is determined whether there is a relationship between variables (Haan, 1977; Sneyers, 1990; Xu, 2002; Onoz and Bayazit, 2003; Bulut *et al.*, 2006).

### **Spearman Rank Correlation Test (SRCT)**

The SRCT is the nonparametric version. It is a fast and simple test used to determine whether there is a significant trend among the observed values. This test is effective, simple and distributed independent in determining the linear and non-linear trends. The test is based on the calculation and testing of the statistic (Sneyers, 1990; Helsel and Hirsch, 1993).

$$R_{sp} = 1 - \frac{6 * \sum_{i=1}^n D_i^2}{(n^3 - n)} \quad (4)$$

Here; n number of cases,  $D_i$  difference in paired ranks. The calculated  $R_{sp}$  value is tested (t) at the degree of freedom and at the 5% significance level (Kottegoda, 1980; Dahmen and Hall, 1990; Kendall and Gibbons, 1990; Sneyers, 1990; Sen, 2002; Kanji, 2006).

$$t = R_{sp} * \sqrt{\frac{n-2}{1-R_{sp}^2}} \quad (5)$$

## **RESULT AND DISCUSSION**

In the study, the meteorological stations in Isparta province and districts (16) were selected and the long-term average daily temperature values were used. Heating and cooling degree-day values for all indoor comfort temperatures suggested in Table 2 for broiler breeding were calculated. They were examined with the parametric LRA to determine the changes in these values and the results are presented in Table 3. The a and b regression coefficients, t statistical t-test, p probability significance level ( $p < 0.05$ ) and r correlation coefficient are indicated in Table 3.

**Table 3.** Results of LRA of heating and cooling degree-day values

| Name of the meteorological station | Selected balance temperatures (°C) |          |          |           |           |           |
|------------------------------------|------------------------------------|----------|----------|-----------|-----------|-----------|
|                                    | 31                                 | 29       | 25       | 23        | 21        | 18        |
| Aksu                               |                                    |          |          |           |           |           |
| HDD                                |                                    |          |          |           |           |           |
| <b>a</b>                           | - 7,800                            | - 7,000  | - 7,530  | - 0,00604 | - 0,00643 | - 0,00639 |
| <b>b</b>                           | 22969,0                            | 20656,0  | 20235,0  | 2020,410  | 2017,890  | 2011,980  |
| <b>t</b>                           | 1,460                              | 1,360    | 1,300    | 64,900    | 71,440    | 85,310    |
| <b>p</b>                           | 0,160                              | 0,191    | 0,208    | 0,000     | 0,000     | 0,000     |
| <b>r</b>                           | 0,221                              | 0,205    | 0,217    | 0,197     | 0,197     | 0,182     |
| CDD                                |                                    |          |          |           |           |           |
| <b>a</b>                           | ---                                | ---      | 0,235    | 0,0695    | 0,0259    | 0,0175    |
| <b>b</b>                           | ---                                | ---      | - 465,0  | 1991,580  | 1990,860  | 1988,010  |
| <b>t</b>                           | ---                                | ---      | - 1,220  | 973,320   | 614,860   | 325,530   |
| <b>p</b>                           | ---                                | ---      | 0,237    | 0,000     | 0,000     | 0,000     |
| <b>r</b>                           | ---                                | ---      | 0,272    | 0,207     | 0,164     | 0,190     |
| Atabey                             |                                    |          |          |           |           |           |
| HDD                                |                                    |          |          |           |           |           |
| <b>a</b>                           | - 2,110                            | - 2,540  | - 1,390  | - 0,00541 | - 0,0001  | 0,00192   |
| <b>b</b>                           | 10950,0                            | 11083,0  | 7356,0   | 2012,990  | 1991,830  | 1986,620  |
| <b>t</b>                           | 2,560                              | 2,660    | 1,850    | 43,100    | 46,900    | 56,760    |
| <b>p</b>                           | 0,014                              | 0,011    | 0,070    | 0,000     | 0,000     | 0,000     |
| <b>r</b>                           | 0,145                              | 0,176    | 0,100    | 0,224     | 0,000     | 0,000     |
| CDD                                |                                    |          |          |           |           |           |
| <b>a</b>                           | 0,000212                           | 0,0388   | 0,713    | 0,129     | 0,0942    | 0,0629    |
| <b>b</b>                           | - 0,415                            | - 76,4   | - 1380,0 | 1975,980  | 1967,650  | 1956,080  |
| <b>t</b>                           | - 0,460                            | - 2,37   | - 2,520  | 412,770   | 293,070   | 168,300   |
| <b>p</b>                           | 0,649                              | 0,022    | 0,015    | 0,000     | 0,000     | 0,000     |
| <b>r</b>                           | 0,707                              | 0,333    | 0,358    | 0,459     | 0,477     | 0,405     |
| Bagkonak                           |                                    |          |          |           |           |           |
| HDD                                |                                    |          |          |           |           |           |
| <b>a</b>                           | - 27,500                           | - 28,100 | - 28,000 | - 0,00376 | - 0,00439 | - 0,00465 |
| <b>b</b>                           | 62232,0                            | 62645,0  | 61072,0  | 2008,610  | 2008,610  | 2008,550  |
| <b>t</b>                           | 0,980                              | 1,010    | 0,970    | 120,200   | 134,510   | 136,940   |
| <b>p</b>                           | 0,356                              | 0,342    | 0,359    | 0,000     | 0,000     | 0,000     |
| <b>r</b>                           | 0,292                              | 0,303    | 0,300    | 0,341     | 0,375     | 0,381     |

*Analysis of trend changes in degree-day values of heating...*

|           |               |               |               |          |          |           |
|-----------|---------------|---------------|---------------|----------|----------|-----------|
| CDD       |               |               |               |          |          |           |
| <b>a</b>  | ---           | ---           | - 0,407       | - 0,100  | - 0,0281 | - 0,00494 |
| <b>b</b>  | ---           | ---           | 814,0         | 1994,220 | 1994,360 | 1989,820  |
| <b>t</b>  | ---           | ---           | 0,870         | 1176,850 | 676,420  | 362,330   |
| <b>p</b>  | ---           | ---           | 0,412         | 0,000    | 0,000    | 0,000     |
| <b>r</b>  | ---           | ---           | 0,292         | 0,549*   | 0,341    | 0,110     |
| Barla     |               |               |               |          |          |           |
| HDD       |               |               |               |          |          |           |
| <b>a</b>  | 76,800        | 74,900        | 70,700        | 0,00361  | 0,00371  | 0,00380   |
| <b>b</b>  | -<br>145775,0 | -<br>142876,0 | -<br>135988,0 | 1994,670 | 1976,530 | 1979,300  |
| <b>t</b>  | - 1,170       | - 1,200       | - 1,100       | 142,970  | 153,290  | 181,860   |
| <b>p</b>  | 0,306         | 0,298         | 0,334         | 0,000    | 0,000    | 0,000     |
| <b>r</b>  | 0,522         | 0,529         | 0,494         | 0,478    | 0,451    | 0,425     |
| CDD       |               |               |               |          |          |           |
| <b>a</b>  | ---           | - 0,0429      | - 5,670       | - 0,0629 | - 0,0349 | - 0,00240 |
| <b>b</b>  | ---           | 85,300        | 11296,0       | 1994,730 | 1996,820 | 2001,390  |
| <b>t</b>  | ---           | 1,730         | 4,210         | 1521,990 | 840,050  | 463,370   |
| <b>p</b>  | ---           | 0,158         | 0,014         | 0,000    | 0,000    | 0,000     |
| <b>r</b>  | ---           | 0,655         | 0,903*        | 0,901*   | 0,843*   | 0,811*    |
| Egirdir   |               |               |               |          |          |           |
| HDD       |               |               |               |          |          |           |
| <b>a</b>  | 4,490         | 4,020         | 4,540         | 0,0145   | 0,0165   | 0,0161    |
| <b>b</b>  | -2283,0       | - 2077,0      | - 4534,0      | 1935,820 | 1937,910 | 1951,910  |
| <b>t</b>  | -0,410        | - 0,370       | - 0,850       | 61,350   | 69,180   | 83,170    |
| <b>p</b>  | 0,683         | 0,711         | 0,397         | 0,000    | 0,000    | 0,000     |
| <b>r</b>  | 0,230         | 0,207         | 0,243         | 0,253    | 0,272    | 0,243     |
| CDD       |               |               |               |          |          |           |
| <b>a</b>  | ---           | 0,00147       | 0,0310        | 0,00307  | 0,0168   | - 0,0160  |
| <b>b</b>  | ---           | - 2,790       | - 36,000      | 1988,510 | 1987,620 | 2000,050  |
| <b>t</b>  | ---           | - 0,320       | - 0,090       | 376,940  | 248,000  | -152,670  |
| <b>p</b>  | ---           | 0,751         | 0,928         | 0,000    | 0,000    | 0,000     |
| <b>r</b>  | ---           | 0,045         | 0,032         | 0,089    | 0,071    | 0,095     |
| Gelendost |               |               |               |          |          |           |
| HDD       |               |               |               |          |          |           |
| <b>a</b>  | 10,100        | 11,500        | 10,400        | 0,00282  | 0,00438  | 0,00527   |
| <b>b</b>  | -13228,0      | - 16688,0     | - 15950,0     | 1974,110 | 1970,560 | 1971,880  |

|           |          |          |          |          |          |          |
|-----------|----------|----------|----------|----------|----------|----------|
| <b>t</b>  | -0,150   | - 0,190  | - 0,190  | 80,860   | 92,020   | 111,930  |
| <b>p</b>  | 0,886    | 0,861    | 0,859    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | 0,114    | 0,126    | 0,122    | 0,228    | 0,330    | 0,361    |
| CDD       |          |          |          |          |          |          |
| <b>a</b>  | ---      | ---      | 0,100    | 0,0291   | 0,0182   | 0,0122   |
| <b>b</b>  | ---      | ---      | - 190,0  | 1983,720 | 1982,550 | 1980,240 |
| <b>t</b>  | ---      | ---      | - 0,040  | 1017,690 | 732,220  | 326,450  |
| <b>p</b>  | ---      | ---      | 0,973    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | ---      | ---      | 0,010    | 0,445    | 0,492    | 0,401    |
| Isparta   |          |          |          |          |          |          |
| HDD       |          |          |          |          |          |          |
| <b>a</b>  | -12,100  | - 11,700 | - 12,600 | - 0,0238 | - 0,0226 | - 0,0211 |
| <b>b</b>  | 30268,0  | 28808,0  | 29087,0  | 2068,230 | 2049,330 | 2026,860 |
| <b>t</b>  | 0,600    | 0,580    | 0,600    | 43,490   | 46,830   | 55,280   |
| <b>p</b>  | 0,563    | 0,576    | 0,568    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | 0,161    | 0,161    | 0,173    | 0,214    | 0,190    | 0,161    |
| CDD       |          |          |          |          |          |          |
| <b>a</b>  | ---      | - 0,0085 | - 0,624  | 0,277    | 0,162    | 0,101    |
| <b>b</b>  | ---      | 16,500   | 1222,0   | 1950,460 | 1940,610 | 1925,090 |
| <b>t</b>  | ---      | 0,550    | 0,800    | 389,590  | 257,500  | 154,950  |
| <b>p</b>  | ---      | 0,597    | 0,448    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | ---      | 0,190    | 0,268    | 0,470    | 0,431    | 0,386    |
| Kasimlar  |          |          |          |          |          |          |
| HDD       |          |          |          |          |          |          |
| <b>a</b>  | 1,600    | 6,700    | 4,500    | 0,00274  | 0,00549  | 0,00858  |
| <b>b</b>  | - 1813,0 | - 6654,0 | - 3868,0 | 1977,850 | 1969,350 | 1965,500 |
| <b>t</b>  | - 0,040  | - 0,160  | - 0,080  | 51,390   | 66,910   | 112,630  |
| <b>p</b>  | 0,971    | 0,883    | 0,937    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | 0,084    | 0,138    | 0,084    | 0,045    | 0,300    | 0,532*   |
| CDD       |          |          |          |          |          |          |
| <b>a</b>  | ---      | ---      | - 0,068  | 0,0442   | 0,0408   | 0,0240   |
| <b>b</b>  | ---      | ---      | 137,0    | 1989,110 | 1986,570 | 1983,340 |
| <b>t</b>  | ---      | ---      | 0,150    | 927,310  | 1028,250 | 883,580  |
| <b>p</b>  | ---      | ---      | 0,889    | 0,000    | 0,000    | 0,000    |
| <b>r</b>  | ---      | ---      | 0,063    | 0,197    | 0,647*   | 0,807*   |
| Keciborlu |          |          |          |          |          |          |



*Analysis of trend changes in degree-day values of heating...*

|           |          |          |          |           |           |            |
|-----------|----------|----------|----------|-----------|-----------|------------|
| HDD       |          |          |          |           |           |            |
| <b>a</b>  | 3,520    | 4,040    | 3,640    | 0,0992    | 0,0118    | 0,0131     |
| <b>b</b>  | - 187,0  | - 1940,0 | - 2598,0 | 1943,870  | 1941,050  | 1947,030   |
| <b>T</b>  | - 0,020  | - 0,160  | - 0,220  | 48,470    | 53,190    | 64,350     |
| <b>p</b>  | 0,988    | 0,874    | 0,828    | 0,000     | 0,000     | 0,000      |
| <b>r</b>  | 0,130    | 0,155    | 0,141    | 0,210     | 0,247     | 0,253      |
| CDD       |          |          |          |           |           |            |
| <b>a</b>  | ---      | - 0,0041 | 0,102    | 0,0267    | 0,0145    | 0,00665    |
| <b>b</b>  | ---      | 8,200    | - 174,0  | 1977,940  | 1977,350  | 1977,140   |
| <b>t</b>  | ---      | 0,170    | - 0,170  | 470,610   | 352,170   | 198,260    |
| <b>p</b>  | ---      | 0,865    | 0,869    | 0,000     | 0,000     | 0,000      |
| <b>r</b>  | ---      | 0,045    | 0,045    | 0,148     | 0,134     | 0,077      |
| Kumdanli  |          |          |          |           |           |            |
| HDD       |          |          |          |           |           |            |
| <b>a</b>  | - 10,200 | - 9,300  | - 10,900 | - 0,00186 | - 0,00120 | - 0,000015 |
| <b>b</b>  | 27125,0  | 24522,0  | 26326,0  | 1996,850  | 1993,520  | 1989,540   |
| <b>t</b>  | 0,580    | 0,540    | 0,580    | 108,470   | 115,160   | 128,490    |
| <b>p</b>  | 0,578    | 0,603    | 0,577    | 0,000     | 0,000     | 0,000      |
| <b>r</b>  | 0,134    | 0,126    | 0,148    | 0,126     | 0,071     | 0,000      |
| CDD       |          |          |          |           |           |            |
| <b>a</b>  | ---      | - 0,0231 | - 0,870  | 0,00859   | 0,0163    | 0,0143     |
| <b>b</b>  | ---      | 46,200   | 1768,0   | 1988,530  | 1985,440  | 1981,450   |
| <b>t</b>  | ---      | 0,550    | 0,710    | 520,330   | 436,520   | 300,420    |
| <b>p</b>  | ---      | 0,592    | 0,496    | 0,000     | 0,000     | 0,000      |
| <b>r</b>  | ---      | 0,170    | 0,214    | 0,084     | 0,279     | 0,363      |
| Senirkent |          |          |          |           |           |            |
| HDD       |          |          |          |           |           |            |
| <b>a</b>  | - 7,690  | - 8,180  | - 6,500  | - 0,0213  | - 0,0202  | - 0,0192   |
| <b>b</b>  | 22031,0  | 22295,0  | 17625,0  | 2076,310  | 2059,950  | 2041,560   |
| <b>t</b>  | 4,150    | 4,250    | 3,550    | 61,090    | 65,540    | 77,800     |
| <b>p</b>  | 0,000    | 0,000    | 0,001    | 0,000     | 0,000     | 0,000      |
| <b>r</b>  | 0,399    | 0,424    | 0,367    | 0,349     | 0,308     | 0,272      |
| CDD       |          |          |          |           |           |            |
| <b>a</b>  | 0,00594  | 0,0580   | 1,190    | 0,125     | 0,0935    | 0,0721     |
| <b>b</b>  | - 11,800 | - 114,0  | - 2318,0 | 1975,380  | 1966,500  | 1950,390   |
| <b>t</b>  | - 1,930  | - 2,190  | - 3,610  | 460,810   | 326,910   | 198,460    |

|               |         |         |          |          |          |          |
|---------------|---------|---------|----------|----------|----------|----------|
| <b>p</b>      | 0,061   | 0,034   | 0,001    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | 0,281   | 0,318   | 0,487    | 0,548*   | 0,561*   | 0,549*   |
| Sutculer      |         |         |          |          |          |          |
| HDD           |         |         |          |          |          |          |
| <b>a</b>      | - 5,690 | - 6,280 | - 4,780  | - 0,0318 | - 0,0301 | - 0,0313 |
| <b>B</b>      | 17741,0 | 18200,0 | 13779,0  | 2106,430 | 2082,020 | 2061,290 |
| <b>t</b>      | 4,860   | 5,060   | 4,030    | 49,540   | 53,040   | 66,200   |
| <b>p</b>      | 0,000   | 0,000   | 0,000    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | 0,416   | 0,456   | 0,381    | 0,370    | 0,374    | 0,316    |
| CDD           |         |         |          |          |          |          |
| <b>a</b>      | 0,00370 | 0,0599  | 0,900    | 0,143    | 0,104    | 0,0737   |
| <b>b</b>      | - 7,320 | - 118,0 | - 1754,0 | 1974,230 | 1964,230 | 1948,550 |
| <b>t</b>      | - 1,490 | - 1,770 | - 3,440  | 434,430  | 291,680  | 157,900  |
| <b>p</b>      | 0,144   | 0,084   | 0,001    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | 0,214   | 0,255   | 0,460    | 0,519*   | 0,525*   | 0,460    |
| Sarkikaraagac |         |         |          |          |          |          |
| HDD           |         |         |          |          |          |          |
| <b>a</b>      | - 5,060 | - 5,350 | - 4,770  | - 0,0116 | - 0,0108 | - 0,0919 |
| <b>b</b>      | 17579,0 | 17427,0 | 14813,0  | 2048,730 | 2037,820 | 2023,480 |
| <b>t</b>      | 2,710   | 2,730   | 2,310    | 55,180   | 60,160   | 69,730   |
| <b>p</b>      | 0,010   | 0,009   | 0,026    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | 0,245   | 0,263   | 0,235    | 0,226    | 0,063    | 0,155    |
| CDD           |         |         |          |          |          |          |
| <b>a</b>      | ---     | ---     | 0,274    | 0,270    | 0,123    | 0,0682   |
| <b>b</b>      | ---     | ---     | - 541,0  | 1987,180 | 1962,910 | 1974,280 |
| <b>t</b>      | ---     | ---     | - 3,540  | 661,900  | 439,780  | 259,400  |
| <b>p</b>      | ---     | ---     | 0,001    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | ---     | ---     | 0,501*   | 0,474    | 0,438    | 0,421    |
| Uluborlu      |         |         |          |          |          |          |
| HDD           |         |         |          |          |          |          |
| <b>a</b>      | - 4,410 | - 4,850 | - 4,010  | - 0,0162 | - 0,0150 | - 0,0137 |
| <b>b</b>      | 15758,0 | 15936,0 | 12804,0  | 2058,440 | 2044,240 | 2028,020 |
| <b>t</b>      | 3,350   | 3,410   | 2,790    | 53,650   | 58,910   | 70,740   |
| <b>P</b>      | 0,002   | 0,001   | 0,008    | 0,000    | 0,000    | 0,000    |
| <b>r</b>      | 0,265   | 0,292   | 0,249    | 0,249    | 0,219    | 0,184    |
| CDD           |         |         |          |          |          |          |

|                |          |          |          |          |          |          |
|----------------|----------|----------|----------|----------|----------|----------|
| <b>a</b>       | 0,000868 | 0,0166   | 0,382    | 0,199    | 0,118    | 0,0787   |
| <b>b</b>       | - 1,720  | - 32,700 | - 741,0  | 1978,020 | 1971,740 | 1957,920 |
| <b>t</b>       | - 2,130  | - 2,140  | - 2,770  | 428,410  | 304,400  | 176,750  |
| <b>p</b>       | 0,038    | 0,037    | 0,008    | 0,000    | 0,000    | 0,000    |
| <b>r</b>       | 0,302    | 0,303    | 0,386    | 0,425    | 0,425    | 0,414    |
| Yalvac         |          |          |          |          |          |          |
| HDD            |          |          |          |          |          |          |
| <b>a</b>       | - 9,120  | - 9,350  | - 8,220  | - 0,0239 | - 0,0209 | - 0,0169 |
| <b>b</b>       | 25396,0  | 25138,0  | 21417,0  | 2097,790 | 2071,650 | 2042,190 |
| <b>t</b>       | 4,870    | 4,860    | 4,250    | 58,090   | 60,170   | 68,670   |
| <b>p</b>       | 0,000    | 0,000    | 0,000    | 0,000    | 0,000    | 0,000    |
| <b>r</b>       | 0,474    | 0,486    | 0,448    | 0,407    | 0,332    | 0,077    |
| CDD            |          |          |          |          |          |          |
| <b>a</b>       | 0,000571 | 0,0310   | 0,893    | 0,177    | 0,117    | 0,0844   |
| <b>b</b>       | - 1,130  | - 61,400 | - 1761,0 | 1981,200 | 1973,570 | 1958,210 |
| <b>t</b>       | - 1,060  | - 2,240  | - 4,090  | 736,440  | 560,880  | 335,590  |
| <b>p</b>       | 0,296    | 0,030    | 0,000    | 0,000    | 0,000    | 0,000    |
| <b>r</b>       | 0,161    | 0,329    | 0,538*   | 0,647*   | 0,691*   | 0,694*   |
| Yenisarbademli |          |          |          |          |          |          |
| HDD            |          |          |          |          |          |          |
| <b>a</b>       | 4,700    | 6,000    | 4,500    | 0,001430 | 0,00268  | 0,00477  |
| <b>b</b>       | - 1982,0 | - 5290,0 | - 3892,0 | 1982,190 | 1978,360 | 1975,730 |
| <b>t</b>       | - 0,040  | - 0,120  | - 0,090  | 96,600   | 108,240  | 132,990  |
| <b>p</b>       | 0,966    | 0,908    | 0,932    | 0,000    | 0,000    | 0,000    |
| <b>r</b>       | 0,063    | 0,084    | 0,063    | 0,095    | 0,173    | 0,249    |
| CDD            |          |          |          |          |          |          |
| <b>a</b>       | ---      | ---      | - 0,095  | 0,0178   | 0,0309   | 0,0225   |
| <b>b</b>       | ---      | ---      | 197,0    | 1987,730 | 1984,480 | 1980,130 |
| <b>t</b>       | ---      | ---      | 0,160    | 884,590  | 666,200  | 402,010  |
| <b>p</b>       | ---      | ---      | 0,874    | 0,000    | 0,000    | 0,000    |
| <b>r</b>       | ---      | ---      | 0,045    | 0,122    | 0,120    | 0,467    |

\* (p<0.05)

The statistical characteristics of each meteorological station are provided in Table 3 and when the heating degree-day values, calculated according to the selected balance temperature values, the results of the LRA and the probability (p<0,05) and correlation coefficients (r) at 5% significance level were compared at the same time, it was identified that there were statistically significant trends

at 18°C in Kasimlar, at 23°C in Bagkonak, at 18-21-23-25°C in Barla, at 21-18°C in Kasimlar, at 18-21-23°C in Senirkent, at 21-23°C in Sutculer, at 25°C in Sarkikaraagac and at 18-21-23-25°C in Yalvac, according to the results of cooling degree-day values. Statistically significant trends at 5% significance level were not found in the heating and cooling values calculated for the other selected balance temperature values for broiler breeding. The calculations of the SRCT were performed for each meteorological station and the results are presented in Figure 1 at 5% significance level to be compared visually.




Figure 1. SRCT graphics for heating and cooling degree-day values

The results of the SRCT of the heating degree-day values calculated according to the selected balance temperature values indicated that there were statistically significant trends in Egirdir at 21°C, in Isparta at 31-29-25-23°C, in Senirkent at 31-29-25-23-21°C, in Sutculer at 31-29-25-23-21-18 °C, in Yalvac at 31-29-25-23-21°C. The results of the SRCT of the cooling degree-day values calculated indicated statistically significant trends in Atabey at 29-25-23-21-18°C, in Barla at 25-23-21°C, in Isparta at 23-21-18°C, in Kasimlar at 18°C, in Senirkent at 31-29-25-23-21-18°C, in Sutculer at all selected balance temperature values, in Sarkikaraagac at 25-23-21-18°C, in Uluborlu at 29-25-23-21-18°C, in Yalvac at 29-25-23-21-18°C. According to the selected balance temperature values, the heating and cooling degree-day values calculated for each meteorological station were examined with the LRA and SRCT and it was determined that the results of the trend were parallel to each other. The studies conducted by Gultekin and Kadioglu (1996) and Kadioglu *et al.* (2001) are similar to our

findings. The heating and cooling degree-day values calculated were examined together with the latitude, longitude and elevations of the meteorological stations indicated in Table 1. It was determined that the heating degree-day value calculated at meteorological stations with a low elevation was low, the cooling degree-day value was high, and the heating degree-day value calculated at meteorological stations with a high elevation was high, and the cooling degree-day value was low.

## **CONCLUSIONS**

The meteorological stations in Isparta province and districts (16) were selected as the study area and the long-term average daily temperature values were used. Heating and cooling degree-day values for all indoor selected balance temperatures in broiler breeding were calculated. The LRA and SRCT were conducted to identify whether there were changes depending on the climatic changes in these values. In conclusion, it was determined that there were statistically significant trends at 5% significance level in Egirdir (21°C), Isparta (31-29-25 and 23°C), Kasimlar (18°C), Senirkent (31-29-25-23 and 21°C), Sutculer (all selected balance temperature values) and Yalvac (31-29-25-23 and 21°C) in terms of heating degree-day values, and in Atabey (29-25-23-21 and 18°C), Barla (25-23 and 21°C), Isparta (23-21 and 18°C), Senirkent (29-25-23-21 and 18°C), Sutculer (29-25-23-21 and 18°C), Sarkikaraagac (25-23-21 and 18°C), Uluborlu (25-23-21 and 18°C) and Yalvac (25-23-21 and 18°C) in terms of cooling degree-day values. This indicated that more energy consumption would be in question in heating and cooling the animal barns to be established in Isparta province depending on the climatic change. Thus, it was determined that the users should be more careful when using the trend values to provide the optimum conditions in the planning and projecting studies of poultry housing they would conduct by using heating and cooling degree-day values.

## **ACKNOWLEDGEMENT**

The authors thank the Turkish State Meteorological Services for providing data.

## **REFERENCES**

Anonymous, (2015). *Broiler Production*, (online) (15.12.2016) Available at: <http://www.tarim.gov.tr> (In Turkish)

Atilgan A., Yucel A., Oz, H. (2012). *Determination of heating and cooling day data for broiler housing: Isparta case*, Journal of Food, Agriculture & Environment 10(3&4):353-356.

Aydin D., Kavak A.F., Toros H. (2015). *Impact on electricity consumption of heating and cooling degree days VII*. Atmospheric Science Symposium, April 28-30, Istanbul, pp.29-39.

Bagdatli, M.C., Istanbuluoglu, A., Alturk, B., Arslan, C. (2014). *Uzun Yıllık Sıcaklık Verilerindeki Değişim Trendinin Tarımsal Kuraklık Açısından Değerlendirilmesi: Çorlu Örneği*, Düzce Üniversitesi Bilim ve Teknoloji Dergisi, 2:100-107. (In Turkish)

Bulut, H., Yesilata, B., Yesilnacar, M. I. (2006). *Atatürk Baraj Gölünün Bölge İklimi Üzerine Etkisinin Trend Analizi İle Tespiti*, GAP V. Mühendislik Kongresi Bildiriler Kitabı, 26-28 Nisan 2006, 79-86, Şanlıurfa. (In Turkish)

Buyukalaca O., Bulut H., Yılmaz T. (2001). *Analysis of variable-base heating and cooling degree-days for Turkey*, Applied Energy, 69:269-283.

Dahmen, E. R., Hall, M. J. (1990). *Screening of Hydrological Data: Tests for Stationary and Relative Consistency*, 58 p., Netherlands.

Demir, D.A., Sahin, U., Demir, Y. (2016). *Murat Nehri Su kalite Parametrelerinin Trend Analizi ve Tarımsal Açısından Kullanılabilirliği*, YYÜ Tar. Bil. Derg., 26(3): 414-420. (In Turkish)

Erturk, M., Kurt, H.A., Kilic, A., Kaya, S. (2015). *Relations of investigation for heating & cooling degree time calculator in latitude, longitude, altitude in the Marmara Region*, 12. National Installation Engineering Congress, April 8-11, Izmir, pp1575-1594.

Gultekin, L., Kadioglu, M. (1996). *Marmara Bölgesinde Isıtma ve Soğutma Derece-Günlerinin Dağılımı*, Tesisat Mühendisliği, Temmuz-Ağustos 1996, 3(31):33-41. (In Turkish)

Haan, C. T. (1977). *Statistical Methods in Hydrology*, Iowa State University Press, Ames, USA.

Hamdi, M. R., Abu-Allaban, M., Al-Shayeb, A., Jaber, M., Momani, N. M. (2009). *Climate Change in Jordan: A Comprehensive Examination Approach*, American Journal of Environmental Sciences, 5(1), 58-68.

Helsel, D. R., Hirsch, R. M. (1993). *Statistical Methods in Water Resources*, Studies in Environmental Sciences: 49, Elsevier, USA.

Kadioglu, M. (1997). *Trends in Surface Air Temperature Data over Turkey*, Int. J.Climatol., 17:511-520.

Kadioglu, M., Sen, Z., Gultekin, L. (2001). *Variation and Trends in Turkish Seasonal Heating and Cooling Degree-Days*, Climatic Change, 49: 209-223.

Kalayci, S., Kahya, E. (1998). *Susurluk Havzası nehirlerinde su kalitesi trendlerinin belirlenmesi*. Journal of Engineering and Environmental Science, 22: 503-514. (In Turkish)

- Kanji, G. K. (2006). *100 Statistical Tests*, 3rd Edition, SAGE Publications, 242 p., New Delhi.
- Kendall, M., Gibbons, J. D. (1990). *Rank Correlation Methods*, Fifth Edition, 260 p., USA.
- Kottegoda, N. T. (1980). *Stochastic Water Resources Technology*, The McMillan Press Ltd., 384 p., London.
- Krese G., Prek M., Butala V. (2012). *Analysis of building electric energy consumption data using an improved cooling degree day method*. Journal of Mechanical Engineering, 58(2): 107-114.
- Kuehn, T.H., Ramsey, J.W., Threlkeld, J.L. (1998). *Thermal Environmental Engineering*, 3<sup>th</sup> Edition, Prentice Hall, New Jersey, 740 pp.
- Lindley J.A., Whitaker J.H. (1996). *Agricultural buildings and structures*, 2nd edition. Technical Books Information Publishing Group, USA, 605 p.
- Onoz, B., Bayazit, M. (2003). *The Power of Statistical Tests for Trend Detection*, Turkish Journal of Engineering and Environmental Sciences, 27:247-251.
- Satman A., Yalcinkaya N. (1999) *Heating and cooling degree-hours for Turkey*, Energy, 24:833-840.
- Shammugasundram, S. (2012). *Statistical Analysis to Detect Climate Change And Its Implication on Water Resources*, School of Engineering And Science, Faculty of Health, Engineering And Science, Victoria University, Australia.
- Singh, D., Gupta, R. D., Jain, S. K. (2015). *Study of Daily Temperature Indices Over Sutlej Basin, N-W Himalayan Region*, India, Global NEST Journal, 17(2):301-311.
- Sneyers, R. (1990). *On The Statistical Analysis of Series of Observations*, WMO Technical Note 143, WMO No: 415, TP-103, Genva, World Meteorological Organization, pp192.
- Sen, Z. (2002). *Hidrolojide Veri İşleme, Yorumlama ve Tasarım, Seminer Notları, 28 Ocak – 2 Şubat, Su Vakfı Yayınları, İstanbul*. (In Turkish)
- Turkes, H. (1996). *Spatial and Temporal Analysis of Annual Rainfall Variations in Turkey*. Int. Journal. Climatol, 16:1057-1076.
- Turkes, M. (2002). *Spatial and Temporal Variations in Precipitation and Aridity Index Series of Turkey in Mediterranean Climate Variability and Trends Regional Climate Studies*, Springer Verlag, Heidelberg, Regional Climate Studies, 181-213.
- Xu, C. (2002). *Textbook of Hydrological Models, Edition 2002*, Uppsala University Department of Earth Sciences Hydrology, Chong-yu Xu 2002-10-20, Uppsala, Sweden.
- Yildiz, I., Sosaoglu B. (2007). *Spatial distributions of heating, cooling, and industrial degree-days in Turkey*. Theoretical and Applied Climatology, 90 (3-4): 249-261.

Yucel, A., Atilgan, A., Oz, H., Saltuk, B. (2014). *The determination of heating and cooling day values using degree-day method: Tomato plant example*. Infrastructure and Ecology of Rural Areas, VI(I):1049-1061.

Corresponding author: Prof Dr Atilgan Atilgan  
Dr Hasan Oz  
Suleyman Demirel University  
Agriculture Faculty  
Agricultural Structure and Irrigation Department  
32260 Isparta, Turkey  
e-mail: atilganatilgan@sdu.edu.tr  
e-mail: hasanoz@sdu.edu.tr

Dr Ali Yucel  
Nuri Erdem  
Osmaniye Korkut Ata University,  
Osmaniye Vocational School,  
Osmaniye, Turkey

Received: 30.03.2017

Accepted: 18.04.2017